

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				T1299		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHRECK, DEL						Phone #													
Mailing Address N4649 MAPLE LN						1. Well Location						Fire # (if avail.)							
City ONALASKA						State WI		Zip Code 54650				Town of TREMPLEAU		N13301					
Street Address or Road Name and Number LARKSPUR RD						Subdivision Name PRAIRIE BLUFFS						Lot # 21		Block #					
County Trempealeau		Co. Permit # 5177		Notification # 22095267		Completed 03-04-2006		Latitude / Longitude in Decimal Degree (DD) 44.0321 °N -91.4259 °W				Method Code GCD013							
Well Constructor (Business Name) LYSAKER WELL DRLG & SERVICE LLC				Lic. # 6968		Facility ID # (Public Wells)				NE SW Section Township Range or Govt Lot # 14 18 N 9 W		Well Plan Approval #							
Address N5452 EAGLE CIRCLE LANE ONALASKA WI 54650				Approval Date (mm-dd-yyyy)		2. Well Type New Well				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? WATE SUPPLY				Construction Type Drilled									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock									
4		Surface		112		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes - - Y -				Type, Caving/Noncaving, Color, Hardness, etc... SAND & GRAVEL		From (ft.) Surface		To (ft.) 112	
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 65 ft. below ground surface				11. Well Is 24 in. above grade					
4		NEW PLAIN END BLACK STEEL ASTM A53B .237 WALL 10.79 LBS WHEATLAND WELDED				Surface		109		10. Pump Test Pumping level 100 ft. below surface Pumping at 10 GP M for 24 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE				13. Constructor / Supervisory Driller EL		Lic # Date Signed 03-04-2006			
3.5		STAINLESS STEEL 10 SLOT CONT JOHNSON				109		112		Drill Rig Operator DL				Lic or Reg # Date Signed 03-04-2006					
7. Grout or Other Sealing Material																			
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller EL				Lic # Date Signed 03-04-2006					
Surface				Surface		Surface		Surface		Drill Rig Operator DL				Lic or Reg # Date Signed 03-04-2006					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		6
Building Drain - Sanitary		15	Sewer - Building Sanitary		25
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 09-14-2006

Updated On: 07-31-2019

Review Status: