

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TJ090		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MILLER, BENNIE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address E5785 HELGESON RD						Town of JEFFERSON						E5786					
City WESTBY						State WI		Zip Code 54667				Street Address or Road Name and Number HELGESON RD					
County Vernon		Co. Permit #		Notification # 26073236		Completed 06-11-2007		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) NORMAN HOLLER				Lic. # 252		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.61457 °N -90.96467 °W				Method Code GPS008			
Address HOLLER PLBG & WELL DRLG LA CROSSE WI 54601				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 10 13 N 5 W				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method														8. Geology			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
10		Surface		168		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... <u>Yes</u> Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 19depth ft. (If NO explain on back side)				T S C M SILT LOAM R H E C CLAY Y H H - SHALE ROCK T F L - LIMEROCK U H L - HARD LIMEROCK T H M - SANDROCK		Surface 8 8 24 24 50 50 138 138 168 168 220					
6		168		220													
6. Casing, Liner, Screen						9. Static Water Level 137 ft. below ground surface				11. Well Is 24 in. above grade							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		10. Pump Test Pumping level 160 ft. below surface Pumping at 10 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
6		ASTM-A53 .280 WALL 18.97 LBS PER FOOT WHEATLAND U.S.A. PLAIN END WELD				Surface 168											
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)											
7. Grout or Other Sealing Material Method PUMPED TREMIE PIPE						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE EXIST											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic # Date Signed					
NEAT CEMENT		Surface		168		79 S		NH				06-22-2007					
						Drill Rig Operator				Lic or Reg # Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		150	Landfill	>	1200
			Ditch or Culvert		300

Comment:

Created On: 09-12-2007

Updated On: 02-09-2023

Review Status: