Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TM781

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHWARZ, JOHN	Phone #: (920)787-1652
Mailing Address: 707 W APPLETREE RD	
City: GLENDALE	State: WI — Zip Code: 53217
County: Waushara	Co. Permit #:
Notification #: 23677017	Completed: 08-28-2006

1. Well Location

Town of MARION

Fire # (if avail.):

Street Address or Road Name and Number: CHIPPER CIR

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): ETHAN A WELCH	Lic. #: 647
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: WELLS BY WELCH FREMONT WI 54940	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3.3	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SE or Govt Lot #: | Section: 8 | Township: 18 N | Range: 11 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	132

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Temp. Outer Casing 10in. dia
- Yes Removed? 20depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND, STONES	Surface	23
-	-	Y	C	SAND, GRAVEL, CLAY	23	101
-	-	Z	-	CLAY, GRAVEL	101	119
-	-	Y	-	SAND, GRAVEL	119	132

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL TC IPSCO ASTM A53B	Surface	128
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS #15	128	132

9. Static Water Level

49 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 20 GP M for 17 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		08-28-2006
Drill Rig Operator	Lic or Reg #	Date Signed
PB		08-28-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Sewer - Building Sanitary		50

Comment:

Created On: 09-25-2006 Updated On: 09-25-2006 Review Status: