Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TM786

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AMBROSIUS, RICHARD			Phone #: (920)277-5589
Mailing Address: 502 LIND ST			
City: FREMONT	State: WI	Zip Code: 54940	
County: Waupaca	Co. Permit #:	Notification #: 23586322	Completed: 08-24-2006

1. Well Location

Town of FREMONT

Fire # (if avail.): 502

Street Address or Road Name and Number: LIND ST

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ETHAN A WELCH	647	

Latitude / Longitude in Decimal Degree (DD): 44.2578 °N -88.8749 °W

Method Code: GCD013

Address: WELLS BY WELCH, FREMONT WI 54940

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

SE	SW	Section	Township	Range
or Govt Lot #		25	21 N	13 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	341

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 10in. dia... No

Dual Rotary .....

Temp. Outer Casing 10in. dia

Yes Removed? 20depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	5
-	-	X	-	CLAY, SAND	5	67
-	-	C	-	CLAY	67	79
-	-	P	-	HARDPAN	79	100
-	-	C	-	CLAY	100	230
-	-	S	U	MUDDY SAND	230	232
-	-	Z	-	CLAY, GRAVEL	232	330
-	-	G	C	GRAVEL, SOME CLAY	330	341

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL TC IPSCO ASTM A53B	Surface	341
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

4 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 25 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB		08-24-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		58	Building Overhang		11
Building Drain - Sanitary		44	Septic or Holding, or POWTS Tank		29

Comment:

Created On: 09-25-2006 Updated On: 05-08-2020 Review Status: