Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TM787

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DITTMAN, MARK			Phone #: (920)725-0007
Mailing Address: 1111 KERWIN RD			
City: NEENAH	State: WI	Zip Code: 54956	
County: Waushara	Co. Permit #:	Notification #: 23698433	Completed: 08-31-2006

Well Constructor (Business Name): ETHAN A WELCH	Lic. #: 647	Facility ID # (Public Wells):	
Address: WELLS BY WELCH FREMONT WI 54940		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of SAXEVILLE				Fire # (if avail.): N7298
Street Address or Road Name and Number: PINE HILL RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.2409 °N -89.0495 °W				Method Code: GCD013
SE NE or Govt Lot #	Section: 3	Township: 20 N	Range: 12 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	65

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Temp. Outer Casing 10in. dia
Yes Removed? 20depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	C	SAND, STONES, CLAY	Surface	7
-	-	S	-	SAND	7	19
-	-	Y	-	SAND, GRAVEL	19	21
-	-	S	-	SAND	21	46
-	-	X	G	SAND, CLAY, STONES	46	57
-	-	Y	-	SAND, GRAVEL	57	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL TC IPSCO ASTM A53B	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS #15	61	65

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 25 GP M for 19 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		08-31-2006
Drill Rig Operator	Lic or Reg #	Date Signed
PB		08-31-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		21
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 09-25-2006 Updated On: 05-05-2020 Review Status: