

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TM787		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DITTMAN, MARK						Phone # (920)725-0007		1. Well Location				Fire # (if avail.)			
Mailing Address 1111 KERWIN RD						Town of SAXEVILLE						N7298			
City NEENAH						State WI		Zip Code 54956				Street Address or Road Name and Number			
PINE HILL RD						Subdivision Name				Lot #		Block #			
County Waushara		Co. Permit #		Notification # 23698433		Completed 08-31-2006		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name)				Lic. # 647		Facility ID # (Public Wells)				44.2409 °N -89.0495 °W		GCD013			
Address WELLS BY WELCH FREMONT WI 54940				Well Plan Approval #		SE NE		Section 3		Township 20 N		Range 12 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 3.6		2. Well Type New Well				of previous unique well #		constructed in	
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled					
Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Rotary - Mud Circulation												
6 20 65			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit 10in. dia...												
			Dual Rotary												
			Temp. Outer Casing 10in. dia												
			Removed? 20depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		STEEL TC IPSCO ASTM A53B				Surface		61		Geology Codes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Type, Caving/Noncaving, Color, Hardness, etc...					
5		SS #15				61		65		From (ft.) To (ft.)					
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level					
CLAY SLURRY				Surface		20				28 ft. below ground surface					
10. Pump Test															
Pumping level 35 ft. below surface															
Pumping at 25 GP M for 19 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
NONE ON PROPERTY															
13. Constructor / Supervisory Driller															
Lic #															
Date Signed															
EW															
08-31-2006															
Drill Rig Operator															
Lic or Reg #															
Date Signed															
PB															
08-31-2006															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		21
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 09-25-2006

Updated On: 05-05-2020

Review Status: