

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TM789		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MAAS, TOM						Phone # (920)988-8474		1. Well Location				Fire # (if avail.)			
Mailing Address W3695 HWY MM						Town of MONROE						778			
City WATERTOWN						State WI		Zip Code 53098				Street Address or Road Name and Number			
18TH AVE						Subdivision Name				Lot #		Block #			
County Adams		Co. Permit #		Notification # 23698402		Completed 08-31-2006		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name)						Lic. # 647		Facility ID # (Public Wells)				44.14413 °N -89.91782 °W		OTH001	
Address WELLS BY WELCH FREMONT WI 54940						Well Plan Approval #		NW SE		Section 4		Township 19 N		Range 5 E	
Hicap Permanent Well #						Common Well #		Specific Capacity 12.5				Reason for replaced or reconstructed well ?			
3. Well serves 1 # of Private, potable						Hicap Well ? No		2. Well Type New Well				of previous unique well #		constructed in	
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Drilled				Reason for replaced or reconstructed well ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		20		Rotary - Mud Circulation									
6		20		84		Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit 10in. dia...				No					
						Dual Rotary									
						Temp. Outer Casing 10in. dia									
						Removed? 20depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		22					
- - X -				CLAY, SAND				22		24					
- - S -				SAND				24		60					
- A Y -				COARSE SAND, GRAVEL				60		84					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL TC IPSCO ASTM A53B				Surface		80							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		SS #15				80		84							
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
CLAY SLURRY				Surface		20									
9. Static Water Level															
39 ft. below ground surface															
10. Pump Test															
Pumping level 41 ft. below surface															
Pumping at 25 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
NONE ON PROPERTY															
13. Constructor / Supervisory Driller															
Lic #															
Date Signed															
EW															
08-31-2006															
Drill Rig Operator															
Lic or Reg #															
Date Signed															
PB															
08-31-2006															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		20
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-25-2006

Updated On: 08-25-2022

Review Status: