Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TN580

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, MICHAEL	Phone #
Mailing Address: 16196 S MORNINGSIDE	
City: WASCOTT	State: WI — Zip Code: 54890
County: Douglas	Co. Permit #: — Notification #: 23037829 — Completed: 08-31-2006
Well Constructor (Business Name): JOHN H HOYER	Lic. #: 5747 — Facility ID # (Public Wells):
Address: 7505 E FLOWAGE RD, MINONG WI 54859	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of WASCOTT	Fire # (if avail.): 16196
Street Address or Road Name and Number: S MORNINGSIDE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.1812 °N -91.955 °W	Method Code: GCD013
NE NW or Govt Lot #:	Section: 26 — Township: 43 N — Range: 13 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ?
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	14
4	14	194

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 14depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	120
-	-	C	G	CLAY & ROCK	120	190
-	-	S	G	SAND & ROCK	190	194

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO STEEL ASTM 53 T&C 11.00 LBS OPEN BOTTOM	Surface	194
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY	Surface	14	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH		08-31-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Shoreline/Pool	>	100
Foundation Drain to Sewer	>	50	Sewer - Building Sanitary		50

Comment:

Created On: 10-04-2006 Updated On: 06-25-2020 Review Status: