

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TN581		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PEDERSON, MARLENE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 6731 W LOWES RD						Town of WASCOTT						6740E	
City EAU CLAIRE						State WI		Zip Code 54701				Street Address or Road Name and Number 6740 E YANO RD	
County Douglas		Co. Permit #		Notification # 23633834		Completed 09-19-2006		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) JOHN H HOYER				Lic. # 5747		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 7505 E FLOWAGE RD MINONG WI 54859				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 26 43 N 13 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8 Surface 14			Rotary - Mud Circulation										
4 14 210			Rotary - Air										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			<u>Yes</u> Cable-tool Bit 4in. dia... <u>No</u>										
			Dual Rotary										
			<u>Yes</u> Temp. Outer Casing 8in. dia										
			<u>Yes</u> Removed? 14depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
- - S -			SAND						Surface 100				
- - C G			CLAY ROCK						100 120				
- - S U			MUDDY SAND						120 194				
- - Y -			SAND & GRAVEL						194 210				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level				11. Well Is	
4		STEEL A53 T&C 11.00 LBS IPSCO OPEN BOTTOM				Surface 210		63 ft. below ground surface				12 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test				Developed ? Yes	
								Pumping level 70 ft. below surface				Disinfected ? Yes	
								Pumping at 10 GP M for 4 Hrs.				Capped ? Yes	
								Pumping Method ?					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
CLAY		Surface 14				Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller													
JH				Lic #		Date Signed							
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		30
Privy		100	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 10-04-2006

Updated On: 10-04-2006

Review Status: