Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TN581

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PEDERSON, MARLENE	Phone #
Mailing Address: 6731 W LOWES RD	
City: EAU CLAIRE	State: WI — Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Douglas		23633834	09-19-2006

Well Constructor (Business Name): JOHN H HOYER	Lic #: 5747
Address: 7505 E FLOWAGE RD, MINONG WI 54859	

Facility ID # (Public Wells)

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #

Specific Capacity: 1.4

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

1. Well Location

Town of WASCOTT

Fire # (if avail.): 6740E

Street Address or Road Name and Number: 6740 E YANO RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

SE	NE	Section	Township	Range
or Govt Lot #		26	43 N	13 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	14
4	14	210

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 4in. dia... No

Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? 14depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	100
-	-	C	G	CLAY ROCK	100	120
-	-	S	U	MUDDY SAND	120	194
-	-	Y	-	SAND & GRAVEL	194	210

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL A53 T&C 11.00 LBS IPSCO OPEN BOTTOM	Surface	210
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

63 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 10 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY	Surface	14	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH		09-19-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		30
Privy		100	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 10-04-2006 Updated On: 10-04-2006 Review Status: