Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TN612

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	GLICK, SAMUEL
Phone #	
Mailing Address	25248 TRUMAN RD
City	BELMONT
State	WI
Zip Code	53510
County	Lafayette
Co. Permit #	
Notification #	24790097
Completed	11-24-2006
Well Constructor (Business Name)	DEAN A KIRSCHBAUM
Lic. #	6536
Facility ID # (Public Wells)	
Address	DON'S WELL DRILLING LLC BOSCOBEL WI 53805
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.1

1. Well Location

Fire # (if avail.)	
Town of	KENDALL
Street Address or Road Name and Number	BETHEL GRV
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	°N °W
Method Code	
SE or Govt Lot #	SE
Section	20
Township	3 N
Range	2 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	84
6	84	220

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 12depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	12
-	-	L	-	LIMEROCK	12	210
-	-	N	-	SANDROCK	210	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	CHINA NEW BLACK STEEL ASTM-A53-B BPE	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

90 ft. below ground surface

10. Pump Test

Pumping level 200 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	84	30 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		12-07-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		212	Animal Barn Pen		102
Building Overhang		9	Septic or Holding, or POWTS Tank		145

Comment:

Created On: 01-08-2007 Updated On: 01-08-2007 Review Status: