

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TN612		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GLICK, SAMUEL						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 25248 TRUMAN RD						Town of KENDALL							
City BELMONT						State WI		Zip Code 53510					
County Lafayette		Co. Permit #		Notification # 24790097		Completed 11-24-2006		Street Address or Road Name and Number BETHEL GRV					
						Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) DEAN A KIRSCHBAUM				Lic. # 6536		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W			
						Well Plan Approval #				Method Code SE SE Section Township Range			
Address DON'S WELL DRILLING LLC BOSCOBEL WI 53805						Approval Date (mm-dd-yyyy)				or Govt Lot # 20 3 N 2 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well			
										of previous unique well # constructed in			
										Reason for replaced or reconstructed well ?			
3. Well serves 1 # of						Hicap Well ? No							
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ?				Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 84			Rotary - Mud Circulation										
6 84 220			No Rotary - Air Yes										
			Yes Rotary - Air & Foam No										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Yes Temp. Outer Casing 10in. dia										
			Yes Removed? 12depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
- - C -			CLAY						Surface		12		
- - L -			LIMEROCK						12		210		
- - N -			SANDROCK						210		220		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		CHINA NEW BLACK STEEL ASTM-A53-B BPE				Surface		84					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PRESSURE TREMIE													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT				Surface		84		30 S					
9. Static Water Level													
90 ft. below ground surface													
10. Pump Test													
Pumping level 200 ft. below surface													
Pumping at 10 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
DK				Lic #		Date Signed							
						12-07-2006							
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		212	Animal Barn Pen		102
Building Overhang		9	Septic or Holding, or POWTS Tank		145

Comment:

Created On: 01-08-2007

Updated On: 01-08-2007

Review Status: