

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TS858		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MCGRIMM LLC						Phone # (608)848-3749							
Mailing Address 1829 SHADY PT DR													
City VERONA				State WI		Zip Code 53593							
County Dane		Co. Permit # 23810		Notification #		Completed 08-31-2004		1. Well Location				Fire # (if avail.) 3753	
Street Address or Road Name and Number COACHMAN WAY													
Subdivision Name TIMBER RIDGE						Lot # 18		Block #					
Well Constructor (Business Name) SAMS ROTARY DRILLERS INC				Lic. # 370		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0538 °N -89.5987 °W		Method Code GCD013	
Address PO BOX 150 RANDOLPH WI 53956-0150				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 30 7 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology				
10 Surface 273			No Rotary - Mud Circulation No			- - Z - Clay & Gravel			From (ft.) To (ft.) Surface 15				
6 273 320			Yes Rotary - Air Yes			- - L - Limestone/Dolomite			15 77				
			No Rotary - Air & Foam No			- - N - Sandstone			77 189				
			No Drill-Through Casing Hammer Reverse Rotary			- - H - Shale			189 255				
			No Cable-tool Bit ___ in. dia... No			- - N - Sandstone			255 295				
			Dual Rotary			- - N H Sandstone, Shaley			295 300				
			Yes Temp. Outer Casing 10in. dia			- - L - Limestone/Dolomite			300 320				
			Yes Removed? 16depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		STD BLK, PIPE, .280 WALL, P.E., A53B WHEATLAND				Surface		273					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method Tremie Pipe - Pumped													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
Neat cement grout				Surface		273		100 S					
9. Static Water Level 179 ft. below ground surface													
10. Pump Test Pumping level 260 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
JVG										08-31-2004			
Drill Rig Operator								Lic or Reg #		Date Signed			
JS										08-31-2004			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 09-07-2004

Updated On: 12-11-2019

Review Status: APPROVED