

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TS862		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHNSON, RUSS & VICKI						Phone # (608)334-4103		1. Well Location				Fire # (if avail.)							
Mailing Address 206 WEBSTER						Town of BEAVER DAM													
City BEAVER DAM						State WI		Zip Code 53916											
County Dodge		Co. Permit #		Notification #		Completed 08-31-2004		Street Address or Road Name and Number COUSINS CRT											
Subdivision Name MILLERS WOODS						Lot # 33		Block #											
Well Constructor (Business Name) SAMS ROTARY DRILLERS INC						Lic. # 370		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)							
Address PO BOX 150 RANDOLPH WI 53956-0150						Well Plan Approval #		°N		°W		Method Code							
								NW		NW		Section 6		Township 11 N		Range 14 E			
Approval Date (mm-dd-yyyy)						or Govt Lot #		6		11 N		14 E							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		2. Well Type New Well					of previous unique well #						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?											
						Hicap Property ? No													
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled											
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
8.75 Surface 63			Yes Rotary - Mud Circulation				No				- - Z S		Clay & Gravel, Sandy		Surface 37				
6 63 122			No Rotary - Air				Yes				- - N -		Sandstone		37 78				
			No Rotary - Air & Foam				No				- - N H		Sandstone, Shaley		78 83				
			No Drill-Through Casing Hammer								- - L -		Limestone/Dolomite		83 122				
			No Reverse Rotary																
			No Cable-tool Bit ___ in. dia...				No												
			Dual Rotary																
			No Temp. Outer Casing ___ in. dia																
			No Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				18 in. above grade				
6			STD BLK, PIPE, .280 WALL, P.E., A53B WHEATLAND				Surface		63		10. Pump Test				Developed ? Yes				
											Pumping level 80 ft. below surface				Disinfected ? Yes				
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes				
											Pumping Method ?								
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Tremie Pipe - Pumped												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed	
Neat cement grout				Surface		63		13 S				JVG				08-31-2004			
												Drill Rig Operator				Lic or Reg #		Date Signed	
												DB						08-31-2004	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment:

Created On: 09-07-2004

Updated On: 09-07-2004

Review Status: APPROVED