Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TX501

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLEIN, RICK	Phone #: (262)749-0773
Mailing Address: N27 W2999 MAPLE AVE	
City: PEWAUKEE	State: WI — Zip Code: 53045
County: Waukesha	Co. Permit #:
Notification #: 23515746	Completed: 08-14-2006
Well Constructor (Business Name): ROCK JOHNSON	Lic. #: 6433
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: DRILL-IT LAKE GENEVA WI 53417	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3.8	

1. Well Location

Town of DELAFIELD

Fire # (if avail.):

Street Address or Road Name and Number: N27 W29999 MAPLE AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW	SW	Section	Township	Range
or Govt Lot #		14	7 N	18 E

2. Well Type Replacement — YP382 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: POINT

Construction Type: Drilled

3. Well serves 1 # of: Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	2
6	2	74

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - Z G	CLAY, GRAVEL, ROCKS BROWN	Surface	16
G - Z -	CLAY, GRAVEL GRAY	16	70
G - H -	SHALE GRAY	70	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR USA ASTM A53 6.625 X .280 GR BE	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 10 ft. below surface

Pumping at 15 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: POURED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CASING SEAL	Surface	0	1.5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJ		08-15-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
		08-15-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Collector Sewer - San or Storm		63
			Shoreline/Pool		95

Comment:

Created On: 10-04-2006 Updated On: 04-12-2016 Review Status: