

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TX501		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KLEIN, RICK Phone # (262)749-0773						1. Well Location				Fire # (if avail.)					
Mailing Address N27 W2999 MAPLE AVE						Town of DELAFIELD									
City PEWAUKEE State WI Zip Code 53045						Street Address or Road Name and Number N27 W29999 MAPLE AVE									
County Waukesha		Co. Permit #		Notification # 23515746		Completed 08-14-2006		Subdivision Name		Lot #	Block #				
Well Constructor (Business Name) ROCK JOHNSON				Lic. # 6433	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code						
Address DRILL-IT LAKE GENEVA WI 53417				Well Plan Approval #		SW	SW	Section 14	Township 7 N	Range 18 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 3.8		2. Well Type Replacement YP382 replaces this well of previous unique well # constructed in									
Reason for replaced or reconstructed well ? POINT															
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock								
8	Surface	2	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)	To (ft.)			
6	2	74					T	-	Z	G	CLAY, GRAVEL, ROCKS BROWN			Surface	16
							G	-	Z	-	CLAY, GRAVEL GRAY			16	70
							G	-	H	-	SHALE GRAY			70	74
6. Casing, Liner, Screen															
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)									
6	WHEATLAND WR USA ASTM A53 6.625 X .280 GR BE				Surface	70									
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)									
7. Grout or Other Sealing Material															
Method POURED															
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement										
CASING SEAL			Surface	0	1.5 S										
8. Geology															
Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)															
T - Z G CLAY, GRAVEL, ROCKS BROWN Surface 16															
G - Z - CLAY, GRAVEL GRAY 16 70															
G - H - SHALE GRAY 70 74															
9. Static Water Level															
6 ft. below ground surface															
10. Pump Test															
Pumping level 10 ft. below surface															
Pumping at 15 GP M for 24 Hrs.															
Pumping Method ?															
11. Well Is															
36 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic # Date Signed															
RJ 08-15-2006															
Drill Rig Operator															
Lic or Reg # Date Signed															
08-15-2006															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Collector Sewer - San or Storm		63
			Shoreline/Pool		95

Comment:

Created On: 10-04-2006

Updated On: 04-12-2016

Review Status: