

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TX983		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KAPINOS, DONALD						Phone # (920)863-6920		1. Well Location				Fire # (if avail.)			
Mailing Address E723 KRINES RD						Town of FRANKLIN									
City DENMARK						State WI		Zip Code 54208							
County Kewaunee		Co. Permit #		Notification # 25239192		Completed 03-12-2007		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) RETZLAFF WELL DRILLING INC				Lic. # 86		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4075 °N -87.7016 °W				Method Code GCD013	
Address PO BOX 81 LUXEMBURG WI 54217-0081				Well Plan Approval #		NW SW		Section 3		Township 22 N		Range 23 E			
						or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type Replacement					
Reason for replaced or reconstructed well ? OLD DUG WELL															
3. Well serves 1 # of				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		51		Yes Rotary - Mud Circulation No									
6		51		123		Rotary - Air									
						No Rotary - Air & Foam Yes									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - C G				CLAY & STONES				Surface		51					
- - L -				LIMESTONE				51		123					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND STEEL PE 18.97 PER FT BLACK NEW ASTM A-53-B MADE IN USA				Surface		51							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
CLAY SLURRY				Surface		51									
9. Static Water Level															
43 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface															
Pumping at 25 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
JR				03-12-2007											
Drill Rig Operator				Lic or Reg #				Date Signed							
KG															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-17-2007

Updated On: 11-25-2019

Review Status: