Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: TX983

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAPINOS, DONALD	Phone #: (920)863-6920
Mailing Address: E723 KRINES RD	
City: DENMARK	State: WI — Zip Code: 54208
County: Kewaunee	Co. Permit #: — Notification #: 25239192 — Completed: 03-12-2007
Well Constructor (Business Name): RETZLAFF WELL DRILLING INC	Lic. #: 86 — Facility ID # (Public Wells):
Address: PO BOX 81 LUXEMBURG WI 54217-0081	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of FRANKLIN

Fire # (if avail.):

Street Address or Road Name and Number: E1368 KRINES RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.4075 °N -87.7016 °W — Method Code: GCD013

NW SW or Govt Lot #: — Section: 3 — Township: 22 N — Range: 23 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD DUG WELL

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	51
6	51	123

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

No — Rotary - Air & Foam ..... — Yes

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONES	Surface	51
-	-	L	-	LIMESTONE	51	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND STEEL PE 18.97 PER FT BLACK NEW ASTM A-53-B MADE IN USA	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

43 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 25 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	51	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR		03-12-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KG		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-17-2007 Updated On: 11-25-2019 Review Status: