

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TX985		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner EUNICE STUECK EST, STUECK, MAR						Phone # (920)323-9230		1. Well Location				Fire # (if avail.)	
Mailing Address 3401 HWY VV						Town of TWO RIVERS							
City TWO RIVERS						State WI		Zip Code 54241					
County Manitowoc		Co. Permit #		Notification # 25253070		Completed 03-16-2007		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) RETZLAFF WELL DRILLING INC				Lic. # 86		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1748 °N -87.5967 °W			
Address PO BOX 81 LUXEMBURG WI 54217-0081				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 26 20 N 24 E				Method Code GCD013			
						Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SAND POINT							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock Yes Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8.75		Surface		83									
6		83		250									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -		SAND				Surface		75					
- - G -		GRAVEL				75		83					
- - L -		LIMESTONE				83		250					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		WHEATLAND STEEL PE 18.97 PER FT BLACK NEW ASTM A53B MADE IN USA				Surface		83					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY Surface 83													
9. Static Water Level 5 ft. below ground surface													
10. Pump Test													
Pumping level 65 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?													
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
JR				Lic #		Date Signed 03-16-2007							
Drill Rig Operator				Lic or Reg #		Date Signed							
KG													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Clearwater Sump		25
Building Overhang		4	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 04-17-2007

Updated On: 10-15-2019

Review Status: