Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TX986

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LAST, JIM		Phone #: (920)863-5947
Mailing Address: 10018 GREENSTREET RD		
City: MARIBEL	State: WI	Zip Code: 54227

County	Co. Permit #	Notification #	Completed
Manitowoc		25277527	03-21-2007

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RETZLAFF WELL DRILLING INC	86	

Address: PO BOX 81
LUXEMBURG WI 54217-0081

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of COOPERSTOWN

Fire # (if avail.):

Street Address or Road Name and Number
10018 GREENSTREET RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.25562 °N	-87.79938 °W			GPS008

SE SW or Govt Lot #	Section	Township	Range
	26	21 N	22 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD 5 IN WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	77
6	77	143

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
No — Rotary - Air & Foam ..... — Yes
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONES	Surface	15
-	-	G	-	GRAVEL	15	30
-	-	L	-	LIMESTONE	30	143

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND STEEL PE 18.97 PER FT BLACK NEW ASTM A53B MADE IN USA	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: PRESSURE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT TREMIE PIPE	Surface	77	15 S

9. Static Water Level
46 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR		03-21-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KG		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		60	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 04-17-2007 Updated On: 10-15-2019 Review Status: