

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TZ108		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KARWOWSKI, MARTIN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 27801 122ND ST						Town of SALEM													
City TREVOR						State WI		Zip Code 53179											
County Kenosha		Co. Permit # 6484		Notification # 6941710701		Completed 01-22-2018		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BLAKE W D & SONS INC				Lic. # 6484		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.50242 °N -88.14493 °W				Method Code UNK001					
Address 42460 N HWY 45 ANTIOCH IL 60002				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 33 1 N 20 E				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of Private, potable				Hicap Well ? No															
Heat Exchange ___ # of drillholes				Hicap Property ? No															
				Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		10		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		No		- - I -		TOP SOIL		Surface		3			
4		10		Y - C S						CLAY, YELLOW, SANDY		3		18					
				U S C -						CLAY, BLUE, SMOOTH		18		35					
				G - C S						CLAY, GREY, SANDY		35		50					
				G N S -						SAND, GREY, FINE		50		60					
				R A S -						SAND, RED, COURSE		60		65					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface				12 in. above grade					
4		STEEL, GALV, A53B 11LBS/FT T&C, R&D WHEATLAND				Surface		61		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 12 ft. below surface				Disinfected ? Yes					
3		STAINLESS 12 SLOT				61		65		Pumping at 15 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method GRAVITY, MOUNDED																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?								No			
CETCO, CRUMBLES		Surface		60		1.5 S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												WDB							
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		27	Foundation Drain to Clearwater		29
Collector Sewer - San or Storm		154	Wastewater Sump		78
			Sewer - Building Sanitary		85

Comment:

Created On: 03-07-2018

Updated On: 02-09-2023

Review Status: