Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TZ465

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TATE, ROBERT	Phone #: (920)915-5834
Mailing Address: E5047 HWY 54	
City: WEYAUWEGA	State: WI — Zip Code: 54983
County: Waushara	Co. Permit #:
Notification #: 24362126	Completed: 02-01-2007
Well Constructor (Business Name): WELLS BY WELCH	Lic. #: 7265
Facility ID # (Public Wells):	
Address: BENTLEY WELL DRILLING LLC, FREMONT WI 54940	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 5	

1. Well Location

Town of SAXEVILLE	Fire # (if avail.): N5760
Street Address or Road Name and Number: 26TH RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
SW SW or Govt Lot #	Section: 20 — Township: 20 N — Range: 12 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	125

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 20depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	1
-	-	S	-	SAND	1	12
R	-	C	S	SANDY RED CLAY	12	48
-	N	S	U	FINE MUDDY SAND	48	80
G	-	C	-	GREY CLAY	80	100
-	-	S	-	SAND	100	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL T/C IPSCO ASTM A53B	Surface	121
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS #10	121	125

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 25 GP M for 19 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		02-01-2007
Drill Rig Operator	Lic or Reg #	Date Signed
PB		02-01-2007

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		18
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-20-2007 Updated On: 03-20-2007 Review Status: