Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TZ482

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUTLIN, MELVIN	Phone #: (262)785-1670
Mailing Address: 14560 W PARK AVE	
City: NEW BERLIN	State: WI Zip Code: 53151
County: Marquette	Co. Permit #:
Notification #: 25029358	Completed: 01-23-2007
Well Constructor (Business Name): WELLS BY WELCH	Lic. #: 7265
Facility ID # (Public Wells):	
Address: BENTLEY WELL DRILLING LLC FREMONT WI 54940	Well Plan Approval #:
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3.6	

1. Well Location

Town of NESHKORO	Fire # (if avail.): N9121
Street Address or Road Name and Number: OTTER LN	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
NW SW or Govt Lot #:	Section: 3 Township: 17 N Range: 11 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: UP TO CODE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	210

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK DIRK	Surface	1
-	-	S	G	SAND, STONES	1	35
-	-	C	S	CLAY W/SAND	35	48
-	-	C	-	CLAY	48	88
-	-	X	-	CLAY, SAND	88	152
I	Q	N	-	CAVEY SANDSTONE-WHITE	152	186
I	H	N	-	FIRM WHITE SANDSTONE	186	210

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL T/C TEXAS TUBULAR	Surface	186
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

1 ft. above ground surface

10. Pump Test

Pumping level 12 ft. below surface

Pumping at 40 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

PLUMBER DID

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		01-23-2007
Drill Rig Operator	Lic or Reg #	Date Signed
PB		01-23-2007

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Shoreline/Pool		85
Building Overhang		8	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-20-2007 Updated On: 10-15-2026 Review Status: