Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TZ483

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MIHOR, WAYNE	Phone #: (262)787-7733
Mailing Address: W6984 S SILVER LAKE RD	
City: WAUTOMA	State: WI — Zip Code: 54982
County: Waushara	Co. Permit #:
Notification #: 25031458	Completed: 01-12-2007
Well Constructor (Business Name): WELLS BY WELCH	Lic. #: 7265
Facility ID # (Public Wells):	
Address: BENTLEY WELL DRILLING LLC, FREMONT WI 54940	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of MARION	Fire # (if avail.): W6984
Street Address or Road Name and Number: S SILVER LAKE RD	
Subdivision Name: CLEAR VIEW	Lot #: 16 — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0503 °N -89.2311 °W	Method Code: GCD013
SE NE or Govt Lot #:	Section: 7 — Township: 18 N — Range: 11 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME UP TO CODE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	92

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 20depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND, STONES	Surface	10
-	-	Y	-	SAND, GRAVEL	10	45
-	-	Y	U	MUDDY SAND, GRAVEL	45	60
-	-	Z	-	CLAY, GRAVEL	60	87
-	-	Y	-	SAND, GRAVEL	87	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL TC IPSCO ASTM A53B	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS #12	88	92

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 68 ft. below surface

Pumping at 15 GP M for 18 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

PLUMBER DID

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		01-12-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
PB		01-12-2007

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		21	Shoreline/Pool		115
			Sewer - Building Sanitary		29

Comment:

Created On: 02-06-2007 Updated On: 05-05-2020 Review Status: