

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TZ483		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MIHOR, WAYNE						Phone # (262)787-7733		1. Well Location				Fire # (if avail.)					
Mailing Address W6984 S SILVER LAKE RD						Town of MARION						W6984					
City WAUTOMA						State WI		Zip Code 54982				Street Address or Road Name and Number S SILVER LAKE RD					
County Waushara		Co. Permit #		Notification # 25031458		Completed 01-12-2007		Subdivision Name CLEAR VIEW				Lot # 16		Block #			
Well Constructor (Business Name) WELLS BY WELCH				Lic. # 7265		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0503 °N -89.2311 °W				Method Code GCD013			
Address BENTLEY WELL DRILLING LLC FREMONT WI 54940				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 7 18 N 11 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME UP TO CODE									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... <u>No</u> Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 20depth ft. (If NO explain on back side)				- - S G SAND, STONES		Surface		10			
6		20		92						- - Y - SAND, GRAVEL		10		45			
										- - Y U MUDDY SAND, GRAVEL		45		60			
										- - Z - CLAY, GRAVEL		60		87			
										- - Y - SAND, GRAVEL		87		92			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		38 ft. below ground surface				24 in. above grade			
6		STEEL TC IPSCO ASTM A53B				Surface		88		10. Pump Test Pumping level 68 ft. below surface Pumping at 15 GP M for 18 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		SS #12				88		92									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method GRAVITY						Filled & Sealed Well(s) as needed? Yes PLUMBER DID											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
CLAY SLURRY		Surface		20													
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						EW						01-12-2007					
						Drill Rig Operator				Lic or Reg #		Date Signed					
						PB						01-12-2007					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		21	Shoreline/Pool		115
			Sewer - Building Sanitary		29

Comment:

Created On: 02-06-2007

Updated On: 05-05-2020

Review Status: