

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TZ484		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner GORSUCH, GLENN						Phone # (920)293-8206		1. Well Location				Fire # (if avail.)					
Mailing Address 526 E PEARL ST						Town of NESHKORO						526					
City NESHKORO						State WI		Zip Code 54960				Street Address or Road Name and Number E PEARL ST					
County Marquette		Co. Permit #		Notification # 25043955		Completed 01-25-2007		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WELLS BY WELCH				Lic. # 7265		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.965 °N -89.2125 °W				Method Code GCD013			
Address BENTLEY WELL DRILLING LLC FREMONT WI 54940				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 8 17 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? UP TO CODE Construction Type Drilled									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well # Common Well # Specific Capacity 2.1													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... <u>No</u> Dual Rotary <u>Yes</u> Temp. Outer Casing ___ in. dia <u>Yes</u> Removed? 20depth ft. (If NO explain on back side)		- - S - SAND Surface 18 - - X G SAND, CLAY, STONES 18 58 - - Y C SAND, GRAVEL, CLAY 58 61 - - Z - CLAY, GRAVEL 61 72 - - Y C SAND, GRAVEL, CLAY 72 78 - - Y - SAND, GRAVEL 78 85									
6		20		85													
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 37 ft. below ground surface				11. Well Is 18 in. above grade			
6		STEEL T/C TEXAS TUBULAR ASTM A53B				Surface		81		10. Pump Test Pumping level 49 ft. below surface Pumping at 25 GP M for 19 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		SS #15				81		85									
7. Grout or Other Sealing Material Method GRAVITY												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No PLUMBER DID					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
CLAY SLURRY				Surface		20											
												13. Constructor / Supervisory Driller Lic # Date Signed EW Drill Rig Operator Lic or Reg # Date Signed PB					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Sewer - Building Sanitary		57

Comment:

Created On: 03-20-2007

Updated On: 04-08-2020

Review Status: