

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UB782		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HOFFMAN, RON & DEBRA						Phone # (715)652-6499		1. Well Location				Fire # (if avail.)					
Mailing Address 3930 MAIN ST						Town of SHERRY											
City MILLADORE						State WI		Zip Code 54454									
County Wood		Co. Permit #		Notification # 19401132		Completed 06-15-2008		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) RICK BRANDL				Lic. # 325		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5851 °N -89.8964 °W				Method Code GCD013			
Address RICK BRANDL WELL DRILLING MILLADORE WI 54454				Well Plan Approval #		SE SW		Section 3		Township 24 N		Range 5 E					
						or Govt Lot #											
Approval Date (mm-dd-yyyy)				2. Well Type New Well		of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of				Hicap Well ? No		Construction Type Drilled											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		40		Rotary - Mud Circulation				- - I -		TOPSOIL		Surface		1	
6		40		180		<u>Yes</u> Rotary - Air		<u>Yes</u>		T - C -		CLAY BROWN		1		4	
						Rotary - Air & Foam				U - C -		CLAY BLUE		4		14	
						Drill-Through Casing Hammer				U H Q -		GRANITE BLUE HARD		14		180	
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						<u>Yes</u> Temp. Outer Casing 8in. dia											
						<u>Yes</u> Removed? 14depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11 ft. below ground surface		18 in. above grade					
6		BLACK STEEL 18.97 ASTM 53 IPSCO WELDED				Surface		40		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 160 ft. below surface		Disinfected ? Yes					
										Pumping at 3 GP for 2 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method BRANDENHEAD												Filled & Sealed Well(s) as needed? No NONE					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
NEAT CEMENT				Surface		40		12 S									
												13. Constructor / Supervisory Driller					
												Lic #		Date Signed			
												RB		06-15-2008			
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200	Clearwater Sump		50
Building Drain - Sanitary		50	Foundation Drain to Clearwater		30
Building Overhang		31	Sewer - Building Sanitary		50
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-19-2009

Updated On: 05-05-2020

Review Status: