

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UB786		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner HOFFMAN, RON & DEBRA						Phone # (715)652-6499		1. Well Location				Fire # (if avail.)											
Mailing Address 3930 MAIN ST						Town of SHERRY																	
City MILLADORE						State WI		Zip Code 54454															
County Wood		Co. Permit #		Notification # 19401212		Completed 03-06-2009		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) RICK BRANDL				Lic. # 325		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5854 °N -89.84848 °W													
Address RICK BRANDL WELL DRILLING MILLADORE WI 54454				Well Plan Approval #		SE SE		Section 3		Township 24 N		Range 5 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?															
						Hicap Property ? No																	
						Hicap Potable ?		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		40		Rotary - Mud Circulation						T - C -		CLAY BROWN		Surface		8					
6		40		200		Rotary - Air				Yes		U - C G		CLAY & STONES BLUE		8		15					
Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing 8in. dia Removed? 15depth ft. (If NO explain on back side)						Yes				U H Q -		GRANITE BLUE HARD		15		200							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				18 in. above grade									
6		BLACK STEEL 18.97 ASTM 53 IPSCO WELDED				Surface		40		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 190 ft. below surface				Disinfected ? Yes									
										Pumping at 1 GP for 1 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method BRANDENHEAD														Filled & Sealed Well(s) as needed? No									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement																	
NEAT CEMENT		Surface		40		9 S																	
13. Constructor / Supervisory Driller														Lic #		Date Signed							
RB																03-06-2009							
Drill Rig Operator														Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		23	Clearwater Sump		16
			Foundation Drain to Clearwater		23

Comment:

Created On: 03-19-2009

Updated On: 03-19-2009

Review Status: