Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UB786

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOFFMAN, RON & DEBRA	Phone #: (715)652-6499
Mailing Address: 3930 MAIN ST	
City: MILLADORE	State: WI — Zip Code: 54454
County: Wood	Co. Permit #:
Notification #: 19401212	Completed: 03-06-2009
Well Constructor (Business Name): RICK BRANDL	Lic. #: 325
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: RICK BRANDL WELL DRILLING MILLADORE WI 54454	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of SHERRY

Fire # (if avail.):

Street Address or Road Name and Number: 9300 ROCKY RUN RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.5854 °N -89.84848 °W

Method Code: GPS008

SE SE or Govt Lot # | Section: 3 | Township: 24 N | Range: 5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 15depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - C -	CLAY BROWN	Surface	8
U - C G	CLAY & STONES BLUE	8	15
U H Q -	GRANITE BLUE HARD	15	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM 53 IPSCO WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 190 ft. below surface

Pumping at 1 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRANDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	40	9 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		03-06-2009
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		23	Clearwater Sump		16
			Foundation Drain to Clearwater		23

Comment:

Created On: 03-19-2009 Updated On: 10-15-2026 Review Status: