

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UB790		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BONTRAGER, DAVID & PERRY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 8136 CO RD K						Town of ARPIN						Street Address or Road Name and Number 8136 CO RD K					
City ARPIN				State WI		Zip Code 54410											
County Wood		Co. Permit #		Notification # 31120242		Completed 11-02-2008		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) RICK BRANDL				Lic. # 325		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5418 °N -89.9839 °W				Method Code GCD013			
Address RICK BRANDL WELL DRILLING MILLADORE WI 54454				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 24 24 N 4 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? MORE WATER & BETTER							
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method								8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		120		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		- - I - TOPSOIL R - C - CLAY RED - - C - CLAY RED & BLUE U - Q - GRANITE BLUE R - Q - GRANITE RED		Surface 1 13 46 90 120		12 ft. below ground surface		19 in. above grade			
6. Casing, Liner, Screen								9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		BLACK STEEL 18.97 ASTM 53 IPSCO WELDED				Surface		46		Pumping level 110 ft. below surface Pumping at 1 GP for 1 Hrs. Pumping Method ?				Filled & Sealed Well(s) as needed? No WANT TO KEEP			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material								12. Notified Owner of need to fill & seal ?									
Method MOUNDED								13. Constructor / Supervisory Driller RB Drill Rig Operator									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement										Lic #	
CRUMBLES		Surface		46		3 S		04-22-2009		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		70	Animal Yard - Include Hutches		75
			Septic or Holding, or POWTS Tank		80

Comment:

OWNER CALLED 010410 & INDICATED NO TEST RESULTS ON NEW WELL FROM DRILLER. WELL IS ONLY 1 GPM. HOUSE IS HOOKED UP TO NEW WELL. WANTS TO KEEP OLD WELL FOR TRAILER. TOLD TO GET ACCEPTANCE BEFORE 060110. SENT NON TO NEW OWNER 030215.

Created On: 05-20-2009

Updated On: 05-05-2020

Review Status: