Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UB790

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	BONTRAGER, DAVID & PERRY
Phone #	
Mailing Address	8136 CO RD K
City	ARPIN
State	WI
Zip Code	54410
County	Wood
Co. Permit #	
Notification #	31120242
Completed	11-02-2008
Well Constructor (Business Name)	RICK BRANDL
Lic. #	325
Facility ID # (Public Wells)	
Address	RICK BRANDL WELL DRILLING MILLADORE WI 54454
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0

1. Well Location

Fire # (if avail.)	
Town of ARPIN	
Street Address or Road Name and Number	8136 CO RD K
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.5418 °N -89.9839 °W
Method Code	GCD013
SW SW or Govt Lot #	
Section	24
Township	24 N
Range	4 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

MORE WATER & BETTER

Construction Type Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
R	-	C	-	CLAY RED	1	13
-	-	C	-	CLAY RED & BLUE	13	46
U	-	Q	-	GRANITE BLUE	46	90
R	-	Q	-	GRANITE RED	90	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 18.97 ASTM 53 IPSCO WELDED	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface	46	3 S

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 110 ft. below surface

Pumping at 1 GP for 1 Hrs.

Pumping Method ?

11. Well Is

19 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

WANT TO KEEP

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		04-22-2009
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		70	Animal Yard - Include Hutches		75
			Septic or Holding, or POWTS Tank		80

Comment: OWNER CALLED 010410 & INDICATED NO TEST RESULTS ON NEW WELL FROM DRILLER. WELL IS ONLY 1 GPM. HOUSE IS HOOKED UP TO NEW WELL. WANTS TO KEEP OLD WELL FOR TRAILER. TOLD TO GET ACCEPTANCE BEFORE 060110. SENT NON TO NEW OWNER 030215.

Created On: 05-20-2009 Updated On: 05-05-2020 Review Status: