Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UB992

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FLESVIG, RAGNER			Phone #
Mailing Address: 1383 BRANDYWINE RD			
City: CROWN POINT	State: IN	Zip Code: 46307	
County: Door	Co. Permit #:	Notification #: 40496350	Completed: 06-01-2011

Well Constructor (Business Name): JORNS, HARVEY	Lic. #: 546	Facility ID # (Public Wells):	
Address: HARVEY & DAVID JORNS WD INC STURGEON BAY WI 54235--980		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of WASHINGTON				Fire # (if avail.): 799
Street Address or Road Name and Number: TOWNLINE RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.37618 °N -88.87292 °W				Method Code: GPS008
NE NE or Govt Lot #	Section: 5	Township: 33 N	Range: 30 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	7
8	7	147
6	147	261

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 8depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - P -	HARDPAN	Surface	5
- - L -	LIMESTONE	5	261

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD WEIGHT BLACK STEEL CASING NEW PLAIN END ASTM A53 WHEATLAND TUBE	Surface	147
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
19 ft. above ground surface

10. Pump Test
Pumping level 155 ft. below surface
Pumping at _____ GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRAIDENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	147	54 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HJ		06-02-2011
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		25

Comment:

Created On: 03-19-2015 Updated On: 04-08-2015 Review Status: