Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UE969

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BLUST, MARIANNE	Phone #: (262)694-1131
Mailing Address: 2221 SPRINGBROOK RD	
City: PLEASANT PRAIRIE	State: WI / Zip Code: 53158
County: Kenosha	Co. Permit #:
Notification #: 6862179201	Completed: 07-17-2017
Well Constructor (Business Name): JOHN J HUEMANN	Lic. #: 5889
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: JOSEPH H HUEMANN & SONS, RINGWOOD IL 60072	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.4	

1. Well Location

Town of PLEASANT PRAIRIE

Fire # (if avail.):

Street Address or Road Name and Number: 2221 SPRINGBROOK RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.538 °N -87.8348 °W	GPS008

SE or Govt Lot #	SE	Section	Township	Range
		13	1 N	22 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: CAME OFF SHARED WELL

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
11	Surface	80
5.87	80	140

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes — Rotary - Mud Circulation ..... — No
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
T	-	C	S	BROWN CLAY & SAND	1	15
G	-	C	-	GRAY CLAY	15	74
-	-	G	G	BOULDERS & GRAVEL	74	75
-	-	L	-	LIMESTONE	75	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 GR B T&C BLK SUMITANO	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: TREMIE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
WYOBEN GROUT	Surface	80	14 S

9. Static Water Level

22.8 ft. below ground surface

10. Pump Test

Pumping level 48.2 ft. below surface

Pumping at 10 GP M for 6 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

CAME OFF SHARED WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		08-14-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		11	Downspout/Yard Hydrant		21
			Foundation Drain to Clearwater		22

Comment:

Created On: 09-12-2017 Updated On: 08-23-2019 Review Status: