

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UG916		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CUTSHALL, ERIC						Phone # (262)470-1167		1. Well Location				Fire # (if avail.)			
Mailing Address 806 PLEASANT ST						Town of SULLIVAN						Street Address or Road Name and Number			
City SULLIVAN						State WI		Zip Code 53178				806 PLEASANT ST			
County Jefferson		Co. Permit #		Notification # 28030131		Completed 11-22-2007		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) RAY R BOWLING				Lic. # 4173		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0122 °N -88.5871 °W				Method Code GCD013	
Address RAY BOWLING INC WATERTOWN WI 53094				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 3 6 N 16 E		2. Well Type Replacement				of previous unique well #		constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? NO WATER				Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		94		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
T	Q	S	-	BR. CAVING SAND-MED		Surface		10							
T	A	Y	-	BR. GRAVEL-SAND-COARSE		10		36							
G	M	C	-	GR CLAY MED-HARD		36		75							
T	B	G	-	BR. BROKEN ROCK-GRAVEL		75		88							
T	-	L	-	BR LIMESTONE		88		94							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		US STEEL PIPE 6.625 X 280 ASTM A53 IPSCO PLAIN END WELDED JOINTS				Surface		88							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
#8 CRUMBLES		Surface		10		1 S									
9. Static Water Level															
20 ft. below ground surface															
10. Pump Test															
Pumping level 20 ft. below surface															
Pumping at 100 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
RB		11-23-2007													
Drill Rig Operator		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Downspout/Yard Hydrant		11
Building Overhang		15	Other Contamination Sources		200
Collector Sewer - San or Storm		75	Sewer - Building Sanitary		15

Comment:

Created On: 03-17-2008

Updated On: 09-26-2019

Review Status: