

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UG917		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCHAEFER, DAVE Phone # (920)261-3908						1. Well Location Fire # (if avail.)									
Mailing Address N1934 CO RD G						Town of LOWELL									
City REESEVILLE State WI Zip Code 53579						Street Address or Road Name and Number N1934 CO RD G									
County Dodge		Co. Permit #		Notification # 27650537		Completed 11-12-2007		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) RAY R BOWLING				Lic. # 4173		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2648 °N -88.8509 °W				Method Code GCD013	
Address RAY BOWLING INC WATERTOWN WI 53094				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 9 9 N 14 E		2. Well Type New Well of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ? HOME					
3. Well serves 1 # of SHOP & HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		285		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T - C G				BR. CLAY & COBBLES				Surface		60					
T - G G				BR. BOULDERS-COBBLES				60		70					
T S N C				BR. SOFT SANDSTONE CLAY COBBLES				70		76					
- - R -				PINK-GRAY QUARTZITE				76		120					
- - Q -				GRAY-BLACK-PINK QUARTZ				120		285					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		US STEEL 6.625 X 280 W. ASTM A53 IPSCO PLAIN END WELDED				Surface		76							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material Method MOUNDED										9. Static Water Level 50 ft. below ground surface					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is 16 in. above grade							
# CRUMBLES		Surface		70		10 S		Developed ? Yes Disinfected ? Yes Capped ? Yes							
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?										13. Constructor / Supervisory Driller Lic # Date Signed RB Drill Rig Operator Lic or Reg # Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Downspout/Yard Hydrant		42
Building Drain - Sanitary		55	Foundation Drain to Clearwater		43
Building Overhang		40	Sewer - Building Sanitary		48
Clearwater Sump		38	Septic or Holding, or POWTS Tank		48

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	11/12/2007	SAMPLE WILL BE LATE WELL NEEDS HYDROFRAC

Created On: 01-11-2008

Updated On: 10-01-2019

Review Status: