Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UG918

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SMALL, ADAM	Phone #: (920)261-6936
Mailing Address: N9096 BEGGAN LN	
City: WATERTOWN	State: WI / Zip Code: 53094
County: Jefferson	Co. Permit #:
Notification #: 27764186	Completed: 11-15-2007
Well Constructor (Business Name): RAY R BOWLING	Lic. #: 4173
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: RAY BOWLING INC WATERTOWN WI 53094	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of WATERTOWN

Fire # (if avail.):

Street Address or Road Name and Number: N9096 BEGGAN LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.1729 °N -88.6595 °W	GCD013

NE SE or Govt Lot #	Section	Township	Range
	12	8 N	15 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	107

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - C G	BR. CLAY & COBBLES	Surface	16
T - G G	BR. COBBLES & GRAVEL	16	44
G - G C	GR. COBBLES ROCK CLAY	44	66
T - L -	BR. LIMESTONE	66	107

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	US STEEL PIPE 6.625 X 280 ASTM A53 IPSCO PLAIN END WELDED	Surface	66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 50 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

28 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 CRUMBLES	Surface	20	2 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		108
Building Drain - Sanitary		41
Building Overhang		10
Clearwater Sump		68

Type	Qualifier	Distance
Downspout/Yard Hydrant		10
Foundation Drain to Clearwater		23
Sewer - Building Sanitary		64
Septic or Holding, or POWTS Tank		118

Comment:

Created On: 01-10-2008 Updated On: 09-26-2019 Review Status: