

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UJ398		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner EICK, DAVID						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1410 CHIPPER LN								Town of FREEMAN							
City SUN PRAIRIE						State WI		Zip Code 53590							
County Crawford		Co. Permit #		Notification # 28096970		Completed 12-17-2007		Street Address or Road Name and Number DESOTO BLUFF RD							
						Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) DONALD D KIRSCHBAUM				Lic. # 6535		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address DON'S WELL DRILLING LLC FENNIMORE WI 53809-1828				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SW		Section 23		Township 11 N		Range 7 W	
								or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		2. Well Type New Well							
								of previous unique well # constructed in							
								Reason for replaced or reconstructed well ?							
								Construction Type Drilled							
3. Well serves 1 # of												Hicap Well ? No			
Private, potable												Hicap Property ? No			
Heat Exchange ____ # of drillholes												Hicap Potable ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 315															
6 315 600															
			Rotary - Mud Circulation												
			Rotary - Air												
			<u>Yes</u> Rotary - Air & Foam <u>Yes</u>												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ____ in. dia...												
			Dual Rotary												
			<u>Yes</u> Temp. Outer Casing 10in. dia												
			<u>Yes</u> Removed? 14depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO A53 B PE				Surface		315							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method PRESSURE TREMIE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		315		175 S							
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - C -		CLAY				Surface		14							
- - L -		LIMEROCK				14		220							
- - N -		SANDROCK				220		280							
- - H -		SHALEROCK				280		510							
- - N -		SANDROCK				510		600							
9. Static Water Level															
440 ft. below ground surface															
10. Pump Test															
Pumping level 580 ft. below surface															
Pumping at 10 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
DDK				Lic #		Date Signed 12-20-2007									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-17-2008

Updated On: 01-17-2008

Review Status: