Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UJ399

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZANCHETTI, MARK			Phone #
Mailing Address: N844 FRANKLIN RD			
City: OCONOMOWOC	State: WI	Zip Code: 53066	
County: Grant	Co. Permit #:	Notification #: 27754358	Completed: 11-16-2007

1. Well Location

Town of WYALUSING

Fire # (if avail.)

Street Address or Road Name and Number: 12050 CO X

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DONALD D KIRSCHBAUM	6535	

Latitude / Longitude in Decimal Degree (DD): 42.94689 °N -91.14033 °W

Method Code: OTH001

Well Plan Approval #:

SW or Govt Lot #	SW	Section: 31	Township: 6 N	Range: 6 W

Address: DON'S WELL DRILLING LLC
FENNIMORE WI 53809-1828

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	94
6	94	260

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 8depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	S	L	-	LOOSE LIMEROCK	Surface	8
-	-	L	-	LIMEROCK	8	220
-	-	N	-	SANDROCK	220	260

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53-B-PE	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

170 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	94	46 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDK		12-20-2007
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		45	Septic or Holding, or POWTS Tank		105

Comment:

Created On: 01-17-2008 Updated On: 09-08-2022 Review Status: