

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UJ400		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KAUFFMAN, GARY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 18289 CO HWY T						Town of WATTERSTOWN									
City BLUE RIVER						State WI		Zip Code 53518				Street Address or Road Name and Number 18289 CO HWY T			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Grant				27634833		11-09-2007									
Well Constructor (Business Name) DONALD D KIRSCHBAUM				Lic. # 6535		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.1638 °N -90.5752 °W				Method Code GCD013	
Address DON'S WELL DRILLING LLC FENNIMORE WI 53809-1828				Well Plan Approval #				SW SE		Section 14		Township 8 N		Range 2 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type Replacement				of previous unique well # LB137 constructed in	
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?					
Private, potable				Hicap Potable ?						Construction Type Drilled					
3. Well serves 1 # of CHICKEN SHED															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		63		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing 10in. dia Removed? 19depth ft. (If NO explain on back side)				No					
6		63		104											
5		104		160											
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - C -		CLAY				Surface		19							
- - H -		SHALEROCK				19		75							
- - N -		SANDROCK				75		160							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO A53B PE				Surface		63							
5		WHEATLAND A53				52		104							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method PRESSURE TREMIE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		63		54 S							
9. Static Water Level															
70 ft. below ground surface															
10. Pump Test															
Pumping level 140 ft. below surface															
Pumping at 10 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?														Yes	
13. Constructor / Supervisory Driller															
DDK														12-20-2007	
Drill Rig Operator														Lic or Reg #	
Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Animal Yard - Include Hutches		54

Comment: SEPTIC/SEWER NOT IN

Created On: 01-17-2008

Updated On: 03-17-2020

Review Status: