Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UJ400

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	KAUFFMAN, GARY
Phone #	
Mailing Address	18289 CO HWY T
City	BLUE RIVER
State	WI
Zip Code	53518
County	Grant
Co. Permit #	
Notification #	27634833
Completed	11-09-2007
Well Constructor (Business Name)	DONALD D KIRSCHBAUM
Lic. #	6535
Facility ID # (Public Wells)	
Address	DON'S WELL DRILLING LLC FENNIMORE WI 53809-1828
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.1

1. Well Location

Town of WATTERSTOWN

Fire # (if avail.)

Street Address or Road Name and Number: 18289 CO HWY T

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 43.1638 °N -90.5752 °W

Method Code: GCD013

SW SE or Govt Lot # | Section: 14 | Township: 8 N | Range: 2 W

2. Well Type Replacement

of previous unique well # LB137 constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CHICKEN SHED

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	63
6	63	104
5	104	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam ..... No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 19depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	19
-	-	H	-	SHALEROCK	19	75
-	-	N	-	SANDROCK	75	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53B PE	Surface	63
5	WHEATLAND A53	52	104
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

70 ft. below ground surface

10. Pump Test

Pumping level 140 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	63	54 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDK		12-20-2007
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Animal Yard - Include Hutches		54

Comment: SEPTIC/SEWER NOT IN

Created On: 01-17-2008 Updated On: 03-17-2020 Review Status: