

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UL441		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner FRANK CHECK BUILDERS						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address PO BOX 125						Town of EGG HARBOR																	
City FRANCIS CREEK						State WI		Zip Code 54214				Street Address or Road Name and Number BIRCHSTONE LN											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #									
Door				28294799		12-31-2007																	
Well Constructor (Business Name) WELLS BY WELCH - ROTARY DIVISION				Lic. # 7500		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Address 9403 TRI COUNTY RD FREMONT WI 54940						Well Plan Approval #		SE SW		Section Township		Range											
						Approval Date (mm-dd-yyyy)		3 29 N		26 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 1.5		2. Well Type New Well				of previous unique well # constructed in											
Reason for replaced or reconstructed well ?																							
3. Well serves 1 # of				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?															
Private, potable				Hicap Potable ?				Construction Type Drilled															
Heat Exchange ___ # of drillholes																							
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)										
8 Surface 175									- - C -		CLAY		Surface 3										
6 175 240									- - L -		LIMESTONE		3 240										
			Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? 3depth ft. (If NO explain on back side)																				
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		133 ft. below ground surface				18 in. above grade									
6		WHEATLAND, STEEL, P/E WELDED, ASTMA53B				Surface		175		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 150 ft. below surface				Disinfected ? Yes									
										Pumping at 25 GP M for 1 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method BRADENHEAD																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No													
NEAT CEMENT GROUT				Surface		175		65 S		NONE ON PROPERTY													
13. Constructor / Supervisory Driller										Lic #		Date Signed											
PB												12-31-2007											
Drill Rig Operator										Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		20
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 02-20-2008

Updated On: 02-20-2008

Review Status: