Well Construction Report
WISCONSIN UNIQUE WELL NUMBER

UL441

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRANK CHECK BUILDERS	Phone #
Mailing Address: PO BOX 125	
City: FRANCIS CREEK	State: WI — Zip Code: 54214
County: Door	Co. Permit #: — Notification #: 28294799 — Completed: 12-31-2007
Well Constructor (Business Name): WELLS BY WELCH - ROTARY DIVISION	Lic. #: 7500 — Facility ID # (Public Wells):
Address: 9403 TRI COUNTY RD, FREMONT WI 54940	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.5

1. Well Location

Town of EGG HARBOR

Fire # (if avail.):

Street Address or Road Name and Number: BIRCHSTONE LN

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE	SW	Section	Township	Range
or Govt Lot #		3	29 N	26 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	175
6	175	240

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 3depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	3
-	-	L	-	LIMESTONE	3	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND, STEEL, P/E WELDED, ASTMA53B	Surface	175
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

133 ft. below ground surface

10. Pump Test

Pumping level 150 ft. below surface

Pumping at 25 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	175	65 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB		12-31-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		20
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 02-20-2008 Updated On: 02-20-2008 Review Status: