

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UL450		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner FABER, DONNA						Phone # (920)361-0912		1. Well Location				Fire # (if avail.)													
Mailing Address W2482 CO H						Town of POY SIPPI						N3406													
City POY SIPPI						State WI		Zip Code 54967				Street Address or Road Name and Number HWY 49													
County Waushara		Co. Permit #		Notification # 28537955		Completed 03-03-2008		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) PATRICK BENTLEY						Lic. # 7036		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1019 °N -88.9858 °W				Method Code GCD013									
Address WELLS BY WELCH/BENTLEY WD LLC FREMONT WI 54940						Well Plan Approval #		NW SW		Section 20		Township 19 N		Range 13 E											
Hicap Permanent Well #						Common Well #		Specific Capacity 0.7				2. Well Type Replacement of previous unique well # constructed in													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? MORE WATER				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method																									
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																						
10 Surface 10			Rotary - Mud Circulation																						
6 10 226			Rotary - Air																						
			Rotary - Air & Foam																						
			Drill-Through Casing Hammer																						
			Reverse Rotary																						
			Cable-tool Bit 10in. dia...																						
			Dual Rotary																						
			Temp. Outer Casing ___ in. dia																						
			Removed? ___ depth ft. (If NO explain on back side)																						
6. Casing, Liner, Screen																									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology															
6		STEEL, T/C, IPSCO ASTM A53B				Surface		226		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - X -		SAND, CLAY		Surface		3									
										- - Z -		CLAY, GRAVEL		3		21									
										- - C S		CLAY, W/SAND LAYERS		21		53									
										- - C -		CLAY		53		93									
										- - Z -		CLAY, GRAVEL		93		114									
										- - C S		CLAY, W/SAND LAYERS		114		225									
										- - G G		STONES, GRAVEL		225		226									
7. Grout or Other Sealing Material														9. Static Water Level				11. Well Is							
Method GRAVITY														11 ft. below ground surface				18 in. above grade							
Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement														10. Pump Test				Developed ? Yes							
CLAY SLURRY, BETONITE Surface 10														Pumping level 45 ft. below surface				Disinfected ? Yes							
														Pumping at 25 GP M for 24 Hrs.				Capped ? Yes							
														Pumping Method ?				Filled & Sealed Well(s) as needed? Yes							
														12. Notified Owner of need to fill & seal ?											
														13. Constructor / Supervisory Driller				Lic #				Date Signed			
														PB				03-03-2008							
														Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		14
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-17-2008

Updated On: 05-05-2020

Review Status: