Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UL703

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COLEMAN, BOB	Phone #: (920)787-0655
Mailing Address: 9110 N 11TH DR	
City: WESTFIELD	State: WI — Zip Code: 53964
County: Marquette	Co. Permit #:
Notification #: 28588147	Completed: 03-14-2008
Well Constructor (Business Name): PATRICK BENTLEY	Lic. #: 7036
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: WELLS BY WELCH/BENTLEY WD LLC FREMONT WI 54940	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 7	

3. Well serves 1 # of GUEST HOUSE
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of NEWTON

Fire # (if avail.): N9110

Street Address or Road Name and Number: 11TH DR

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 43.97178 °N -89.39294 °W
Method Code: OTH001

SW SE or Govt Lot #: | Section: 2 | Township: 17 N | Range: 9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	65

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	3
-	-	C	-	CLAY	3	5
-	-	C	G	CLAY, STONES	5	14
-	-	S	-	SAND	14	25
-	-	Y	C	SAND, GRAVEL, CLAY	25	38
-	-	Y	-	SAND, GRAVEL	38	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, IPSCO, T/C, ASTM A53B	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S.S. #12	61	65

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY, BETONITE	Surface	10	S

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 19 ft. below surface
Pumping at 35 GP M for 18 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE TO ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB		03-14-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		30
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 04-17-2008 Updated On: 09-08-2022 Review Status: