

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UL720		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DAKOTA PARK LLC						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1845 N WARREN								Town of DAKOTA									
City MILWAUKEE				State WI		Zip Code 53202											
County Waushara		Co. Permit #		Notification #		Completed 03-13-2008		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) PATRICK BENTLEY				Lic. # 7036		Facility ID # (Public Wells) 47002714				Method Code							
Address WELLS BY WELCH/BENTLEY WD LLC FREMONT WI 54940				Well Plan Approval #				or Govt Lot #		Section 1		Township 18 N		Range 10 E			
				Approval Date (mm-dd-yyyy)				2. Well Type New Well									
Hicap Permanent Well #				Common Well #		Specific Capacity 20				Reason for replaced or reconstructed well ? TEST WELL							
3. Well serves # of Municipal/Community Test Well						Hicap Well ? No											
Heat Exchange ___ # of drillholes						Hicap Property ? No											
						Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing 10in. dia Removed? 10depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		10						- - I -		TOPSOIL		Surface		1	
6		10		120		- - Y C		SAND, GRAVEL, CLAY		1		10					
						- - Y -		SAND, GRAVEL		10		40					
						- - S U		SAND, MUDDY		40		60					
						- - Y C		SAND, GRAVEL, W/CLAY		60		94					
						- - S -		SAND		94		120					
						- - Z S		SAND, W/CLAY, STONES		120		120					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology							
6		STEEL, IPSCO, ASTM A53B T/C				Surface		112		Type, Caving/Noncaving, Color, Hardness, etc...							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		From (ft.) To (ft.)							
5		S.S. #15				112		120		36 ft. below ground surface							
7. Grout or Other Sealing Material Method WELL ABANDONED										9. Static Water Level							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test							
CASING REMOVED				Surface		120				Pumping level 38 ft. below surface Pumping at 40 GP M for 1 Hrs. Pumping Method ?							
										11. Well Is _____ in. _____ Grade Developed ? No Disinfected ? No Capped ? No							
										12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller						Lic #		Date Signed									
PB								03-13-2008									
Drill Rig Operator						Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Sewer - Building Sanitary		25

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	03/13/2008	BENTONITE 0-120' 40 SACKS USED	TEST WELL

Created On: 11-10-2008

Updated On: 05-07-2013

Review Status: