Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UL720

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAKOTA PARK LLC | Phone #:

Mailing Address: 1845 N WARREN

City: MILWAUKEE | State: WI | Zip Code: 53202

County	Co. Permit #	Notification #	Completed
Waushara			03-13-2008

Well Constructor (Business Name): PATRICK BENTLEY | Lic. #: 7036 | Facility ID # (Public Wells): 47002714

Address: WELLS BY WELCH/BENTLEY WD LLC
FREMONT WI 54940

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #:

Common Well #:

Specific Capacity: 20

1. Well Location

Town of DAKOTA

Fire # (if avail.):

Subdivision Name: | Lot #: | Block #:

Method Code:

or Govt Lot #	Section	Township	Range
	1	18 N	10 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?
TEST WELL

Construction Type: Drilled

3. Well serves # of

Municipal/Community | Test Well

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	120

Upper Enlarged Drillhole | Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Yes Temp. Outer Casing 10in. dia
Yes Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
-	-	Y	C	SAND, GRAVEL, CLAY	1	10
-	-	Y	-	SAND, GRAVEL	10	40
-	-	S	U	SAND, MUDDY	40	60
-	-	Y	C	SAND, GRAVEL, W/CLAY	60	94
-	-	S	-	SAND	94	120
-	-	Z	S	SAND, W/CLAY, STONES	120	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, IPSCO, ASTM A53B T/C	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	S.S. #15	112	120

7. Grout or Other Sealing Material

Method WELL ABANDONED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CASING REMOVED	Surface	120	

9. Static Water Level

36 ft. below ground surface

10. Pump Test

Pumping level 38 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

_____ in.
_____Grade

Developed ? No

Disinfected ? No

Capped ? No

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB		03-13-2008
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Sewer - Building Sanitary		25

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	03/13/2008	BENTONITE 0-120' 40 SACKS USED	TEST WELL

Created On: 11-10-2008 Updated On: 05-07-2013 Review Status: