Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UM676

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: XP LLC			Phone #: (847)778-9101
Mailing Address: W3167 WILDWOOD LN			
City: LAKE GENEVA	State: WI	Zip Code: 53147	
County: Walworth	Co. Permit #:	Notification #: 24041490	Completed: 11-14-2007

Well Constructor (Business Name): JAMES E CHENEY	Lic. #: 339	Facility ID # (Public Wells):	
Address: CHENEY WELL DRILLING ELKHORN WI 53121-9470		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of POND
Private, non-potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SUGAR CREEK

Fire # (if avail.)

Street Address or Road Name and Number: COBBLESTONE

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
NE NE or Govt Lot #	Section: 33	Township: 3 N	Range: 16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	117

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	-	CLAY & GRAVEL	Surface	115
-	-	G	-	GRAVEL	115	117

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO TUBULAR P/E ASTM GR B A-53	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		75 S

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
17 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JC		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Shoreline/Pool		52

Comment: NO BLDG OVERHANG, SEPTIC/SEWER

Created On: 01-17-2008 Updated On: 03-05-2008 Review Status: