

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UN716		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WIS DNR					Phone # (608)266-2621		1. Well Location				Fire # (if avail.)				
Mailing Address 101 S WEBSTER ST							Town of ST MARIE								
City MADISON					State WI Zip Code 53707-7721		Street Address or Road Name and Number								
County Green Lake		Co. Permit #		Notification # 41292407		Completed 08-16-2011		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) MICHAEL J JAKUBOWSKI					Lic. # 538		Latitude / Longitude in Decimal Degree (DD) 43.85462 °N -89.11065 °W				Method Code GPS008				
Address JAKUBOWSKI WELL DRILLING WILD ROSE WI 54984					Facility ID # (Public Wells)		SE NE		Section 31		Township 17 N		Range 12 E		
					Well Plan Approval #		or Govt Lot #								
					Approval Date (mm-dd-yyyy)		2. Well Type New Well								
Hicap Permanent Well #					Common Well #		Specific Capacity 0.7		of previous unique well # constructed in						
3. Well serves # of WHOOPING CRANE					Hicap Well ? No		Reason for replaced or reconstructed well ?								
Private, potable					Hicap Property ? No										
Heat Exchange ___ # of drillholes					Hicap Potable ? No		Construction Type Jetted								
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
2		Surface		35						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...			
						No Rotary - Mud Circulation		No		- - S -		SAND			
						No Rotary - Air		No		- - C -		CLAY			
						No Rotary - Air & Foam		No		- - S -		SAND			
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit 2in. dia...		No							
						No Dual Rotary		No							
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		1 ft. below ground surface		18 in. above grade			
2		T&C WHEATLAND				Surface		32		10. Pump Test		Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 15 ft. below surface		Disinfected ? Yes			
1.25		STAINLESS STEEL POINT 10 SLOT				32		35		Pumping at 10 GP M for 2 Hrs.		Capped ? Yes			
7. Grout or Other Sealing Material												Pumping Method ?			
Method												12. Notified Owner of need to fill & seal ?		No	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?		No			
				Surface											
13. Constructor / Supervisory Driller												Lic #		Date Signed	
MJ														08-17-2011	
Drill Rig Operator												Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 09-08-2011

Updated On: 04-26-2022

Review Status: