

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				UN717		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WEGENKE, DARWIN						Phone # (920)787-2986		1. Well Location				Fire # (if avail.)			
Mailing Address N2263 STATE RD 22						Town of DAKOTA						N2263			
City WAUTOMA						State WI		Zip Code 54982				Street Address or Road Name and Number STATE RD 22			
County Waushara		Co. Permit #		Notification # 41105195		Completed 08-12-2011		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) MICHAEL J JAKUBOWSKI				Lic. # 538		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0608 °N -89.2969 °W				Method Code GCD013	
Address JAKUBOWSKI WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		NW SE		Section 3		Township 18 N		Range 10 E		or Govt Lot #	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type Replacement of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?					
Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		170		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		26					
- - C -				CLAY				26		162					
- - S -				SAND				162		170					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		T&C 257 WALL IPSCO				Surface		166							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		STAINLESS STEEL 10 SLOT				166		170							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
16 ft. below ground surface															
10. Pump Test															
Pumping level 70 ft. below surface															
Pumping at 10 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
15 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
MJ				Lic #		Date Signed									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		15
			Septic or Holding, or POWTS Tank		55

Comment:

Created On: 09-08-2011

Updated On: 05-05-2020

Review Status: