Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UN718

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CCS PROPERTIES	Phone #: (920)632-4815
Mailing Address: 1048 GLORY RD STE C	
City: GREEN BAY	State: WI — Zip Code: 54304
County: Waushara	Co. Permit #:
Notification #: 41773686	Completed: 10-04-2011
Well Constructor (Business Name): MICHAEL J JAKUBOWSKI	Lic. #: 538
Facility ID # (Public Wells):	
Address: JAKUBOWSKI WELL DRILLING, WILD ROSE WI 54984	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of WAUTOMA	Fire # (if avail.): 1048
Street Address or Road Name and Number: STATE RD 22	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
NE NE or Govt Lot #	Section: 1 — Township: 19 N — Range: 10 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
TOO CLOSE TO SEPTIC
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	104

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 4in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	3
-	-	C	-	CLAY	3	13
-	N	S	-	FINE SAND	13	96
-	A	S	-	COARSE SAND	96	104

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	T & C IPSCO 257 WALL #589	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL 10 SLOT	100	104

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 12 GP for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		10-08-2011
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65
Building Overhang		7

Type	Qualifier	Distance
Downspout/Yard Hydrant		12
Foundation Drain to Sewer		35
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 10-31-2011 Updated On: 10-31-2011 Review Status: